



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>UNIVERSITY VILLAGE CSUSB</b>				REINSPECTION DATE <b>Next Routine</b>	INSPECTOR <b>Jonathan Lara</b>	DATE <b>8/28/2018</b>
LOCATION <b>1577 W NORTHPARK BL, SAN BERNARDINO, CA 92407</b>				PERMIT EXPIRATION	IDENTIFIER: Pool	
TIME IN <b>12:50 PM</b>	TIME OUT <b>1:25 PM</b>	FACILITY ID <b>FA0012827</b>	RELATED ID <b>PR0016813</b>	PE <b>3603</b>	SERVICE: 001 - INSPECTION - ROUTINE	
				RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE		
				ACTION: 01 - NO FURTHER ACTION REQUIRED		




**RECREATIONAL HEALTH - Public School Pool / Spa**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

**97**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	150
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

See the following pages for the code sections and general requirements that correspond to each violation listed below.



## RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME UNIVERSITY VILLAGE CSUSB	DATE 8/28/2018
LOCATION 1577 W NORTHPARK BL, SAN BERNARDINO, CA 92407	INSPECTOR Jonathan Lara

### 36K527 Safety – Safety signs

POINTS <b>1</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3120B	Inspector Comments: 1. Observed large multiple safety sign to be broken.  Replace safety signs, ensure they are legible.  2. Observed the following safety information missing:  - Facility name and address - Local emergency service name and phone number  Provide the missing safety information.  3. Observed pool hours of operation to be peeling off sign.  Replace pool hours of operation information.
--------------------	------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with ""CAUTION"" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

### 36K576 Maintenance – Operation/Incident records

POINTS <b>1</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65523	Inspector Comments: Observed incomplete daily records of chemical test results.  Maintain daily records of chemical test results, even on days without pool service.
--------------------	------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

### 36K582 Maintenance - Public pool site maintenance

POINTS <b>1</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65535	Inspector Comments: Observed filter gauge below the START mark.  Backwash/ clean filter and mark new START position.
--------------------	------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

### Overall Inspection Comments

No summary comments have been made for this inspection.



Public Health  
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME UNIVERSITY VILLAGE CSUSB	DATE 8/28/2018
LOCATION 1577 W NORTH PARK BL, SAN BERNARDINO, CA 92407	INSPECTOR Jonathan Lara

Signature(s) of Acknowledgement

NAME: SNA  
TITLE:

Total # of Images: 0