



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CAL STATE UNIVERSITY			REINSPECTION DATE Next Routine	INSPECTOR Jonathan Lara	DATE 8/28/2018
LOCATION 5500 UNIVERSITY PKWY, SAN BERNARDINO, CA 92407			PERMIT EXPIRATION	IDENTIFIER: Coussoulis Old Pool SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED	
TIME IN 1:35 PM	TIME OUT 10:40 PM	FACILITY ID FA0006500	RELATED ID PR0014826	PE 3603	

RECREATIONAL HEALTH - Public School Pool / Spa



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

100

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	83
volume (gal)	29,920
area (sq ft)	No Data
occupancy	50

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

36K952 Drained Pool or Spa Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	Observed pool to be drained.
	Violation Reference - HSC	If pool will become operational once again, contact Public Health office at call 1-800-442-2283

Description: An inspection was conducted at this time on a drained pool or spa. Contact DEHS prior to filling with water and/or operating.

Overall Inspection Comments

If pool will become operational once again, contact Public Health office at call 1-800-442-2283

Signature(s) of Acknowledgement

SNA

NAME: SNA
TITLE:

Total # of Images: 0