



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CAL STATE UNIVERSITY		REINSPECTION DATE Next Routine	INSPECTOR Yvette Velasco	DATE 10/13/2015
LOCATION 5500 UNIVERSITY PKWY, SAN BERNARDINO, CA 92407		PERMIT EXPIRATION	IDENTIFIER: Coussoulis New Pool	
TIME IN 11:35 AM	TIME OUT 12:21 PM	FACILITY ID FA0006500	RELATED ID PR0014825	PE 3603
		SERVICE: 001 - INSPECTION - ROUTINE		
		RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE		
		ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - Public School Pool / Spa




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

96
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	82.0
observed flow (gpm)	No Data
required flow (gpm)	978
volume (gal)	352,372
area (sq ft)	6,075
occupancy	122

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the pH levels at 7.1.
	Not In Compliance	
	Violation Reference - HSC - 65530	Ensure to maintain pH levels at 7.2-7.8.

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no sign provided for the nearest emergency facility.
	Not In Compliance	
	Violation Reference - CCR - 3120B	Ensure to provide all appropriate signs in the pool area.

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CAL STATE UNIVERSITY	DATE 10/13/2015
LOCATION 5500 UNIVERSITY PKWY, SAN BERNARDINO, CA 92407	INSPECTOR Yvette Velasco

36K566 Lighting – Requirements

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed seven (7) lights in the pool non-functional.
	Not In Compliance	Ensure to repair or replace the lights as soon as possible.
	Violation Reference - CCR - 3115B	<u>Inspector will follow up during the next routine inspection.</u>

Violation Description: Pools shall have underwater and deck lighting such that lifeguards or other persons may observe, without interference from direct and reflected glare from the lighting sources, every part of the underwater area and pool surface, all diving boards or other pool appurtenances.

36K593 Supervision – Non-Critical – Certified lifeguards

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed several lifeguard certifications expired.
	Not In Compliance	Ensure to provide valid lifeguard certifications for all lifeguards on site.
	Violation Reference - HSC - 116045, 65539	

Violation Description: Lifeguard service shall be provided for any public swimming pool that is of wholly artificial construction and for the use of which a direct fee is charged. For all other public swimming pools, lifeguard service shall be provided or signs shall be erected clearly indicating that the service is not provided.

If the pool operator provides lifeguard services, they shall be provided in accordance with Health and Safety Code sections 116028, 116033, and 116045. The pool operator shall ensure that written proof of compliance with the certification requirements of Health and Safety Code sections 116028 and 116033 for each lifeguard is available for inspection by the enforcing agent at the public pool.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0